



MOUNTAIN IRON

Public Works Department ♦ 8586 Enterprise Drive North ♦ Mountain Iron, MN 555768

Phone: 218-748-7570 ♦ tsatrang@ci.mountain-iron.mn.us

FIRE HYDRANT INSPECTION FORM

Hydrant ID #:		Location on Property:				
Inspection Date:		Inspector Name:				
Property Owner:						
Property Address:						
Hydrant Type (check one):	59	Clow	Muller	Pacer	Other:	
Year Built:						

TESTING, INSPECTION & MAINTENANCE	PASS	FAIL	IF FAILED, EXPLAIN
1) Hydrant can be easily opened/closed and nut is in good condition?			
2) Hydrant opened fully and flowed until clear?			
3) Hydrant barrel is free from cracks, leaks, physical damage and corrosion?			
4) Does hydrant barrel drain?			
5) Is hydrant accessible for fire department use? (minimum 3' clearance around hydrant)			
6) Does hydrant have marker?			
7) All caps not damaged, rotating smoothly, cap gaskets present and outlet connection threads lubricated and in good condition?			

FAILED items shall be corrected IMMEDIATELY by a city approved contractor.

MNFC Section 507.5.3 Fire hydrant systems shall be maintained in an operative condition at all times, and shall be repaired where defective.

PLEASE CALL 218-748-7570 WHEN FAILED ITEMS ARE FIXED FOR REINSPECTION.

Upon completion of inspection was hydrant tagged OUT OF SERVICE?

YES

NO